

COUNTY OF HARNETT  
Building Inspections Department  
Planning Services

**Certificate of Compliance:** ✓ **Occupancy:** \_\_\_\_\_

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Wesley & Jessica Jarruel

Address: 510 Rollins Mill rd.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Date: 4/2/18

Building Official: [Signature]

**Permit Numbers**

Building: 17-50040872

Electrical: "

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

ADDRESS : 510 ROLLINS MILL RD  
CONTRACTOR : PRESTIGE POOLS  
OWNER : JARRIEL WESLEY & JESSICA  
PARCEL : 05-0626- - -0052- -04-  
APPL NUMBER: 17-50040872 CP SWIMMING POOL

SUBDIV:  
PHONE : (919) 349-4739  
PHONE :

DIRECTIONS : T/S: 03/03/2017 08:21 AM JBROCK ----  
510 ROLLINS MILL RD - 401 TO CHRISTIAN  
LIGHT RD TO COKESBURY RD TO WADE  
STEPHENS

**STRUCTURE: 000 000 20X40 INGROUND POOL**

FLOOD ZONE : FLOOD ZONE X  
PROPOSED USE : INGROUND POOL SEPTIC - EXISTING? : NA

**PERMIT: CSEL 00 CP ELECTRICAL STANDALONE**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E215 01	4/11/17	BS	R*ELEC. UND. POOL VRU #: 002956769
	4/11/17	DA	T/S: April 11, 2017 09:02 AM BSUTTON ----- Conduit must be 18 inches deep in all locations.
E215 02	4/13/17	BS	R*ELEC. UND. POOL VRU #: 002957937
	4/13/17	AP	T/S: April 13, 2017 12:25 PM BSUTTON -----
E205 01	4/27/17	BS	R*ELEC UNDER SLAB VRU #: 002964616
	4/27/17	AP	T/S: April 27, 2017 11:29 AM BSUTTON ----- Only 1 pour cup installed adjacent to skimmer box. Check at final for any other handrails/ladders/diving boards.
R131 01	4/02/18	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 003108818
	<u>11</u>	<u>AP</u>	T/S: 03/29/2018 02:35 PM BPETRICH -----

COMMENTS AND NOTES

*Completed*