



Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

August 30, 2017

Jeremy & Jessica Williams
593 Miller Road
Benson, NC 27504

RE: Existing Tank Application HTE# 17-5-42093

Mr. Williams,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover Outlet lid on septic tank and break seal. (*\$25.00 fee incurred*)
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. Other – Gate locked with German Shepards.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

James Manhart III, R.E.H.S
Environmental Health Program Specialist
Harnett County Department of Public Health
Environmental Health

JM/kh

Copy - Central Permitting