

HTE# 17-5-421902

Harnett County Department of Public Health

30158

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Chad & Nicole Donovan PROPERTY LOCATION: 106 Grahamridge Ln. (Rawls Ch. rd. SR 1415)
 SUBDIVISION Wyndem Place PH 2 LOT # 7
 NEW REPAIR EXPANSION RELOCATION Site Improvements required prior to Construction Authorization Issuance:
 Type of Structure: Ext 3BR SFD
 Proposed Wastewater System Type: 25% reduction Sys
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: C max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] Date: 08/07/2018 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Chad & Nicole Donovan PROPERTY LOCATION: 106 Grahamridge Ln. (Rawls Ch. rd. SR 1415)
 SUBDIVISION Wyndem Place PH 2 LOT # 7

Facility Type: Ext 3BR SFD New Expansion Repair Relocation
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% reduction system (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable 25% reduction Sys - (Repair))

Installation Requirements/Conditions

Septic Tank Size <u>Ext</u> gallons	Number of trenches <u>3 (new)</u>	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Exact length of each trench <u>60 (new)</u> feet	Soil Cover: <u>8-10</u> inches
	Trenches shall be installed on contour at a	(Maximum soil cover shall not exceed
	Maximum Trench Depth of: <u>20-26</u> inches	36" above the trench bottom)
	(Trench bottoms shall be level to +/- 1/4"	
	in all directions)	
Pump Requirements: _____ ft. TDH vs. _____ GPM		Aggregate Depth: <u>NA</u> inches below pipe
		<u>NA</u> inches above pipe
		<u>NA</u> inches total

Conditions: Reference notes on Site Sketch

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 08/07/2018
ANDREW WRAIN Construction Authorization Expiration Date: 08/07/2023

HTE# 175-421902

Permit # 30158

Harnett County Department of Public Health Site Sketch

SL 1415

PROPERTY LOCATOR: 106 Grahamridge Ln (Rawls Cho rd.)

ISSUED TO: Chad & Nicole Donovan SUBDIVISION Wyndam Place PH2 LOT # 7

Authorized State Agent: [Signature] Date: 08/07/2018
ANDREW CORAW



- * UNPERMITTED POOL ON SITE
- * THREE(3) NEW COFT 25% REDUCTION SYS. REQUIRED TO RELOCATE EXT LINES
- 2 LINES UNDER POOL
- 1 LINE DOES NOT MEET 15 FT SETBACK
- * DECKS ARE APPROVED W/ 5 FT SETBACK MAINTAINED ON DRAINFIELD AND SEPTIC TANK
- * LEFT AND REAR PROPERTY LINES SHALL BE MARKED W/ IRONS PRESENT
- * DEEP (20IN) TO SHALLOW (6IN) MAY BE REQUIRED