

HTE #: 18-5-43532

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Charles Dixon Phone #: 937.371.9669

Address: 43 Hamilton Farm Circle Fuquay-Varina, NC 27526

Name of Mobile Home Park or S/D: Olive Branch S/D

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): Olive Branch Rd (SR 1430) / Kipling Rd (SR 1403)

Purpose of Inspection: Above Ground Swimming Pool (21' Diameter) - Proposed pool not within septic field, repair area, or 15ft pool septic setbacks.

Above ground pool located in permitted gravity septic repair area. Pump to repair may be required and/or above ground pool removed in event of repair.


The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

03/21/2018
Date