

HTE# 1650038494

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Andrea Puricelle PHONE # 804-271-2500

ADDRESS Re: 1330 Temple Rd. Burlington

NAME OF MOBILE HOME PARK OR S/D NA

NAME OF OWNER (IF DIFFERENT) Kurt + Kendra Winpegler

ADDRESS OF OWNER (IF DIFFERENT) 1330 Temple Rd. Burlington

PROPERTY LOCATION: STATE ROAD NAME AND # Temple Rd.

PURPOSE OF INSPECTION:

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

John H. Boyd R.E.H.S. 04/26/16
Signature of Environmental Health Specialist Date