



Harnett County
 420 Mckinney Pkwy
 LILLINGTON, NC 27546
 Phone:
 Fax:

12/7/2022

**SUBJECT: CPTS18-50043413
 BUILDING RESIDENTIAL**

To: MARTIN ROBERT

Here are the results of all Inspections located at **54 WILLIFORD LN:**

Inspection Type: ONE TRADE FINAL
 Scheduled Date/Time: 2/28/2018
 Completed Date/Time: 2/28/2018
 Inspector: Unassigned
 Result: DISAPPROVED
 Remarks:
 Notes: T/S: 02/27/2018 08:55 AM LLUCAS -----
 HAD PERMIT PREVIOULY FOR FIRE IN KITCHEN NEVER FINALED. NEED TO fix all loose receptacle & switches & install covers throughout house. Holes in ceiling & floors broken windows in house, no flooring in house.

Inspection Type: FINAL**
 Scheduled Date/Time: 3/19/2019
 Completed Date/Time: 3/19/2019
 Inspector: Unassigned
 Result: DISAPPROVED
 Remarks:
 Notes: Meter base no longer meets code.

Inspection Type: FINAL**
 Scheduled Date/Time: 3/22/2019
 Completed Date/Time: 3/22/2019
 Inspector: Scott Guy
 Result: DISAPPROVED
 Remarks:
 Notes: would like afternoon - call if you have questions or can't do afternoon 919-842-9899
 Not a habitable space. Missing heat and being remodeled.





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 4/23/2019
Completed Date/Time: 4/23/2019
Inspector: Scott Guy
Result: APPROVED W/EXC

Remarks:

Notes: Did the inspection to the best of my ability due to the environment and obstructions.