PREPARED 6/11/18, 14:13:16 Harnett County

INSPECTION TICKET INSPECTOR: IVR

PAGE

32 DATE 6/12/18

ADDRESS . : 284 BRET RD

SUBDIV: CLEARWATER LAKES

CONTRACTOR : AIR RICH HEATING RICHARD JONES

PHONE: (910) 245-3301 PHONE: (919) 499-5008

OWNER . . : TOLLEVSEN MARGARET

PARCEL . .: 09-9767- - -0027- - -

APPL NUMBER: 18-50043703 CP STANDALONE TRADE - RESIDENTIAL

R131 02

DIRECTIONS: T/S: 04/03/2018 10:27 AM BPETRICH --

284 BRET ROAD CAMERON 28326

TAKE 87, LEFT ON MILTON WELCH RD, RIGHT

ON PONDEROSA, QUICK LEFT ONTO BRET ROAD. HOME SITS BEHIND (AND MAY USE

SAME DRIVEWAY AS) 280 BRET RD.

STRUCTURE: 000 000 HVAC C/O HEAT PUMP REPLACEMENT

FLOOD ZONE . . . : FLOOD ZONE X

PROPOSED USE . . . . . : MECH/ELEC WATER SUPPLY . . . . . : UNKNOWN

PERMIT: CPMR 00 CP MECHANICAL RESIDENTIAL

REQUESTED INSP DESCRIPTION TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R131 01 4/26/18 TSG ONE TRADE FINAL VRU #: 003116845
4/26/18 DA Customer has requested AM appt. if possible, please call

ahead. 919-721-8390. Thank you.

LOWER PANEL TRAPPED BY UPPER PANEL, COUD NOT ACCESS HEAT

BREAKER.

ONE TRADE FINAL VRU #: 003137858

Customer has requested AM appt. if possible, please call

ahead 919-721-8390.

----- COMMENTS AND NOTES -----