



THE UNDERSIGNED HEREBY ACKNOWLEDGES THAT THE LAND SHOWN ON THIS PLAT IS WITHIN THE ZONING JURISDICTION OF HARNETT COUNTY AND THAT THIS PLAT AND ALLOTMENT IS MY OR OURS FREE ACT AND DEED FOREVER ALL AREAS SHOWN OR INDICATED ON SAID PLAT

DATE \_\_\_\_\_ OWNER/AGENT SIGNATURE \_\_\_\_\_

NORTH CAROLINA HARNETT COUNTY  
 Mickey R Bennett, PLS do certify that this plat was drawn under my supervision/under description recorded in Book \_\_\_\_\_ Page \_\_\_\_\_ that the boundaries not surveyed are clearly indicated as drawn from information found in Book \_\_\_\_\_ Page \_\_\_\_\_ that the ratio of precision as calculated is 1:10000 that this plat was prepared in accordance with G.S. 47-30 as amended Witness my original signature, registration number and seal this \_\_\_\_\_ day of \_\_\_\_\_ 2008

SEE \_\_\_\_\_ REF \_\_\_\_\_  
 13 TH



MICKEY R BENNETT  
 L-1514

Mickey R Bennett, hereby certify that this survey is of another subject, both as the recombination of existing parcels, a court ordered survey, a division of land or other exception to the definition of subdivision.

DEED REFERENCE  
 DEED BOOK 1088 PAGE 784  
 DEED BOOK 1242 PAGE 811

MAP REFERENCE  
 MAP BOOK 14 PAGE 12  
 MAP NO. 2006-230

THIS PROPERTY IS EXEMPT FROM HARNETT COUNTY SUBDIVISION REGULATIONS.

PLANNING DIRECTOR

STATE OF NORTH CAROLINA COUNTY OF HARNETT  
 REVIEW OFFICER OF HARNETT COUNTY CERTIFY THAT THE MAP OR PLAT TO WHICH THIS CERTIFICATION IS AFFIXED MEETS ALL STATUTORY REQUIREMENTS FOR RECORDING

DATE \_\_\_\_\_ REVIEW OFFICER \_\_\_\_\_

NORTH CAROLINA HARNETT COUNTY  
 This Map/Plat was presented for registration and recorded in this office at Map Number 2006-

This \_\_\_\_\_ day of \_\_\_\_\_ 2008 at \_\_\_\_\_ o'clock \_\_\_\_\_ M

KIMBERLY S. HARGROVE Register of Deeds

By \_\_\_\_\_ Assistant/Deputy Register of Deeds

- LEGEND**
- LINE NOT SURVEYED  
 LINE SURVEYED  
 EP—EXISTING IRON PIPE  
 ECM—EXISTING CONCRETE MONUMENT  
 ES—EXISTING IRON STAKE  
 SPNS—EXISTING P.N.NAL SPINS  
 PKNLS—P.N.NAL SET  
 ELS—EXISTING LIGHTWOOD STAKE  
 NF—NOW OF FORMALLY  
 RW—RIGHT OF WAY  
 CL—CENTER LINE  
 NSI—NEW IRON STAKE  
 NP—NEW IRON PIPE  
 ERRS—EXISTING RAILROAD SPIKE  
 NPS—NEW GALVANIZED SPIKE  
 CP—CALCULATED POINT  
 SMR—EXISTING MAGNETIC NAL  
 MNM—NEW MAGNETIC NAL  
 ECS—EXISTING COTTON SPINDLE  
 NCS—NEW COTTON SPINDLE  
 ERS—CONTROL CORNERS  
 ECM/PROVCS (CONTROL CORNERS)  
 CDB—CHORD BEARING AND DISTANCE  
 DE—DRAINAGE EASEMENT



**PRELIMINARY PLAT**  
 NOT FOR RECORDATION  
 CONVEYANCES OR SALES


LOT RECOMBINATION

SURVEY FOR:  
**JOANN CLARK**

TOWNSHIP	ANDERSON CREEK	COUNTY	HARNETT
STATE	NORTH CAROLINA		
DATE	FEBRUARY 13, 2008		
ZONE	RA-20M	WATERSHED DISTRICT	N/A
TAX PARCEL ID #	SEE REF.	TAX PARCEL ID #	SEE REF.

**BENNETT SURVEYS, INC.**  
 1662 CLARK RD., LILLINGTON, N.C. 27546  
 (910) 893-5252

15' 0 30'	SURVEYED BY:	MRB	FIELD BOOK
SCALE: 1"= 30'	DRAWN BY:	MRB	DRAWING NO.
CHECKED & CLOSURE BY:	MRB		08043



NORTH REFERENCE MAP NO. 2006-230

OWNER LARRY F. CLARK SR ESTATE  
 % JOANN CLARK  
 918 BETHEL BAPTIST RD  
 SPRING LAKE, NC 28390  
 (910) 487-6508

# Southeastern Soil & Environmental Associates, Inc.

P.O. Box 9321  
Fayetteville, NC 28311  
Phone/Fax (910) 822-4540  
Email meaker3851@aol.com

**MEMO (10/5/2007)**

**To: Bill Pannhoff, B & B Catering**

**From: Mike Eaker**

**Re: Additional area needed**

**See attached design:**

**You will need to add an area 50 feet by 135 feet to rear portion of property to accommodate the repair area.**

**Once you have added this area on the survey map (by Mickey Bennett), you should submit the new map and a copy of this report to the Harnett County Health Department.**

**You must apply for a septic permit through the Health Department at which time they will conduct their own investigation based on my recommendations.**

# Southeastern Soil & Environmental Associates, Inc.

P.O. Box 9321  
Fayetteville, NC 28311  
Phone/Fax (910) 822-4540  
Email meaker3851@aol.com

October 5, 2007

Harnett County Health Department  
307 Cornelius Harnett Blvd.  
Lillington, NC 27546

Re: Soil/site evaluation for subsurface waste disposal, proposed B & B Catering facility,  
Bethel Baptist Road, Harnett County, North Carolina

To whom it may concern,

A soil/site evaluation has been conducted on the aforementioned property. The purpose of the investigation was to determine if soils were acceptable for subsurface waste disposal systems to serve a proposed catering facility (all food prepared on site to be taken and served off-site). All ratings and determinations were made in accordance with "Laws and Rules for Sanitary Sewage Collection, Treatment, and Disposal, 15A NCAC 18A .1900".

The proposed facility should have a flow not to exceed 370 gallons per day (see attached water consumption information provided by Harnett County Public Utilities to the owner.) Further, O consulted Trish Angoli with the NCDEHNR engineering section. She recommended using a flow of 5 gallons per meal. According to the owner, this facility will prepare about 150 meals per week. This is sufficiently under the proposed 370 gallons per day.

Based on this flow estimate, at least one site was located on the tract containing soils that have provisionally suitable properties exceeding 36 inches. The site essentially lies on a linear slope (1 - 2%) landscape. Soil borings conducted in most of this area consisted of 12 or more inches of loamy sand underlain by sandy clay loam and/or sandy loam extending to 42 or more inches. Soil wetness was typically observed greater than 42 inches below the soil surface. All other soil characteristics were either suitable or provisionally suitable to at least 42 inches.

Based on soil borings and site conditions, the site would be designated provisionally suitable for a subsurface waste disposal system (may require the use of pumps, innovative drain line, LPP, pretreatment, fill, etc.). The site contains enough provisionally suitable area, as required, to allow for subsurface repairs. A map showing the approximate location of the site and proposed design accompanies this report. **[Note: No grading or soil disturbance can occur in these areas prior to obtaining a permit from the Harnett County Health Department. Any grading without a permit can alter the findings of this report.]**


This report, of course, does not guarantee, constitute or imply that a permit will be issued by the Harnett County Health Department. Because professional differences of opinion sometimes occur, we recommend obtaining a permit from the Harnett County Health Department prior to making any financial commitments for your intended use. This is the only "guarantee" of a site's suitability.

This report only represents my professional opinion as a licensed soil scientist. Permits will only be granted if health department personnel concur with the findings of this report.

Sincerely,




Mike Eaker  
NC Licensed Soil Scientist





# Southeastern Soil & Environmental Associates, Inc.

P.O. Box 9321  
Fayetteville, NC 28311  
Phone/Fax (910) 822-4540  
Email meaker3851@aol.com



Bethel Baptist Church

Water Consumption Information

for

B&B Catering Kitchen  
95 Killdeer Drive  
Spring Lake, NC 28390

	<u>GPD</u>
June 2006	7430 / 30 = 248
July 2006	4200 / 31 = 135
August 2006	2730 / 31 = 88
September 2006	4520 / 30 = 151
October 2006	8170 / 31 = 263
November 2006	9590 / 30 = 320
December 2006	9910 / 31 = 320
January 2007	9260 / 31 = 299
February 2007	5330 / 29 = 184
March 2007	8040 / 31 = 259
April 2007	3780 / 30 = 126
May 2007	8300 / 31 = 268
June 2007	7640 / 30 = 255
July 2007	6680 / 31 = 215
August 2007	3250 / 31 = 105
September 2007	4990 / 30 = 166

HIGH Flow = 320 gpd

use 370 gpd for 15% allowance