

01-5-3280

1 NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15563

OPERATIONS PERMIT

Name: (owner) ROY LEWIS ☒ New Installation ☒ Septic Tank
Property Location: SR# 1401 ROLLINS RD ☐ Repairs ☒ Nitrification Line
Subdivision _____ Lot # _____
TAX ID# _____ Quadrant # _____
Contractor: TONY CARROLL Registration # _____
Basement with Plumbing: ☐ Garage: ☐
Water Supply: ☐ Well ☒ Public ☐ Community
Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☒ Conventional ☐ Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 3 of each ditch 135 ft. ditches 3 ft. ditches 36-20 in.
French Drain: _____ Linear feet

PERMIT NO. 17654

Date: 6/26/02
Inspected by: [Signature]
Environmental Health Specialist

