

03-5-5467

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15893

OPERATIONS PERMIT

Name: (owner) HAL OWEN New Installation Septic Tank
 Property Location: SR# 1418 RIVER RD Repairs Nitrification Line
 Subdivision CAPTAINS LANDING Lot # 23
 TAX ID# _____ Quadrant # _____
 Contractor: TEO BROWN Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 1 exact length of each ditch 400 ft. width of ditches 3 ft. depth of ditches 18 in.
 French Drain: _____ Linear feet

Date: 5/16/03

PERMIT NO. 19655

Inspected by: [Signature]
Environmental Health Specialist

NO REPAIR
NEEDED

