

Harnett County Government Complex  
307 Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547  
fax: 910-893-9371

June , 2008

Timothy Mallett  
50 Sweet Bayberry Ct.  
Sanford, NC 27332

HTE# for ET only: 08-5-20146

Dear Mr. Mallett,

On June 5, 2008 I visited your site and found what appears to be a crushed section of chamber panels within your drainfield. You will need to have a septic tank contractor meet me on site to dig up and replace damaged chamber panels.

If you have any questions I can be contacted between 8-9am at 910-893-7547.

Sincerely,



Joe West, R.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

JW/sgw

Damaged Panels Replaced  
on - 6-19-08