

08-500-20146  
HTE# 08 500-20364

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Timothy Mallet PHONE # 499-5672

ADDRESS 50 Sweet Bayberry Ct Sanford

NAME OF MOBILE HOME PARK OR S/D Crestview Lot 237

NAME OF OWNER (IF DIFFERENT) Car

ADDRESS OF OWNER (IF DIFFERENT) \_\_\_\_\_

PROPERTY LOCATION: STATE ROAD NAME AND # 1115

PURPOSE OF INSPECTION: Storage shed & Deck  
08 500-20146 08 500-20364

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

J. Car  
Signature of Environmental Health Specialist

06.26.08  
Date