



June 11, 2009

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Rosita Dianne Jernigan  
204 Saddle Lane  
Lillington, NC 27546

ph: 910-893-7547  
fax: 910-893-9371

**RE: Harnett County Land Use Application for Existing Tank # 09-5-22240**

Dear Ms. Jernigan,

The Harnett County Department of Public Health, Environmental Health Division on June 10, 2009, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a proposed storage building, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- 15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system.**
- 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.**
- 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line. (Your proposed building will be on the drain field. You also need to replace the handles on septic tank lid.)**

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

James E. Manhart, III, R. S.  
Environmental Health Specialist  
Harnett County Department of Public Health  
Environmental Health Section

JEM/sgs