

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

May 13, 2010

Chris M. Robinson
60 Ruth Circle
Fuquay Varina, NC 27526

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Septic System Inspection HTE# 10-5-24336

Dear Mr. Robinson,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal, wrong lid uncovered (\$25.00 fee incurred)

2. Have system pumped out

3. Replace sanitary T

4. Other

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart, III, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health
Environmental Health

JEM/sgs
Copy - Central Permitting