COUNTY OF HARNETT **Building Inspections Department** Planning Services Certificate of Compliance: Occupancy: Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following: **Permit Numbers** Building: 12-500 29383 Electrical: 17 500 75 383 Insulation: Plumbing: ____ Mechanical: MFG Home: **Building Official:**

an and a survival and the contract of the cont

	12/03/12, 1 ounty		INSPECTION TICKET PAGE INSPECTOR: IVR DATE	
CONTRACTO OWNER . PARCEL .	. : MASSEY . : 12-0555	JERRY L 0005	PHONE : PHONE :	
	S : T/S: 07 401 SOU THEN GO	/16/2012 1 TH TO BYRD	V STORAGE BLDG RESIDENTIAL L2:41 PM DJOHNSON MILL RD TURN RIGHT S MILES HOME ON LEFT.	
STRUCTURE: 000 000 30X60 PERSONAL WORKSHOP FLOOD ZONE : FLOOD ZONE X PROPOSED USE : PERSONAL SHOP SEPTIC - EXISTING? : YES WATER SUPPLY : COUNTY				
	COMPLETED	INSP RESULT	RMIT DESCRIPTION RESULTS/COMMENTS	
B101 01		JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU # T/S: 08/24/2012 04:32 PM VBROWNTHIS IS A MONO SLAB INSPECTION Footing for mono slab to be 12"from the grade to the bottom of the footing	needs
	· '.	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #	
R229 01		KS DA	TWO TRADE FINAL TIME: 17:00 VRU #: 002307122 T/S: 11/26/2012 01:32 PM KSLATTUM You cannot parallel your neutral and ground wire neutral to one bar and ground to the other. Disconne	s. Put
R229 02	12/04/12 /2-4-12	AP SH	tie bar and use bonding screw on ground bar. New protection on receptacles. TWO TRADE FINAL TIME: 17:00 VRU #: 002311231 T/S: 12/03/2012 11:10 AM VBROWN	ed gfci

PREPARED 11/21/12, 14:04:43 INSPECTION TICKET PAGE 12 Harnett County INSPECTOR: IVR DATE 11/26/12 ADDRESS . : 1959 BYRDS POND RD SUBDIV:

CONTRACTOR :

PHONE : OWNER . . : MASSEY JERRY L PHONE : PARCEL . . : 12-0555- - -0005- -

APPL NUMBER: 12-50029383 CP NEW STORAGE BLDG RESIDENTIAL

DIRECTIONS : T/S: 07/16/2012 12:41 PM DJOHNSON --

401 SOUTH TO BYRD MILL RD TURN RIGHT THEN GO APPROX 2.5 MILES HOME ON LEFT.

PREMISE # 24925510

STRUCTURE: 000 000 30X60 PERSONAL WORKSHOP

FLOOD ZONE . . . : FLOOD ZONE X

PROPOSED USE : PERSONAL SHOP SEPTIC - EXISTING? : YES

WATER SUPPLY : COUNTY

11-26

__________ PERMIT: CPBP 00 CP BUILDING PERMIT REQUESTED INSP DESCRIPTION RESULT RESULTS/COMMENTS COMPLETED RESULT TYP/SO B101 01 8/28/12 JH R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002271070 8/28/12 DA T/S: 08/24/2012 04:32 PM VBROWN -----THIS IS A MONO SLAB INSPECTION Footing for mono slab needs to be 12"from the grade to the bottom of the footing. R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002271864 B101 02 8/29/12 JH 8/29/12 AP O Q 11/26/12 TWO TRADE FINAL TIME: 17:00 VRU #: 002307122

------ COMMENTS AND NOTES -----