

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Res Detached Garage

Name: Donald B & Jullie A Jones

Address: 986 Wilburn Road

Fuquay Varina NC 27526

Date: 02/19/2016

Permit Numbers

Building: 15-50035994

Electrical: 15-50035994

~~Mechanical~~

~~Plumbing~~

~~Mechanical~~

~~MFG Home~~

Building Official: Brad Sutton

THE UNIVERSITY OF CHICAGO
 1100 SOUTH EAST ASIAN AVENUE
 CHICAGO, ILLINOIS 60607-7073

PREPARED 2/18/16, 14:55:17
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 15
DATE 2/19/16

ADDRESS : 986 WILBURN RD
CONTRACTOR :
OWNER : JONES DONALD B & JULLIE A
PARCEL : 08-0641- - -0012- -01-
APPL NUMBER: 15-50035994 CP NEW STORAGE BLDG RESIDENTIAL
DIRECTIONS : T/S: 04/27/2015 10:25 AM LBENNETT --
MAKE LEFT ONTO HWY 401; TURN LEFT ON
WILBURN RD.; LAST HOUSE ON WILBURN RD.
ON THE LEFT.

SUBDIV: DIVISION OF W L SENTER ESTATE
PHONE :
PHONE :

STRUCTURE: 000 000 30X44 STORAGE BUILDING/SHOP

FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : BUILDING/SHOP SEPTIC - EXISTING? : YES
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B111 01	9/02/15 9/02/15	BS DA	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002712289 T/S: September 02, 2015 10:56 AM BSUTTON ----- Per engineered slab plan, two piers are missing at front of building. See circled. Correct and reschedule.
B111 02	9/03/15 9/03/15	BS AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002713253 T/S: September 03, 2015 11:35 AM BSUTTON -----
R229 01	2/17/16 2/17/16	BS DA	TWO TRADE FINAL TIME: 17:00 VRU #: 002777621 T/S: 02/16/2016 12:57 PM LBENNETT ----- T/S: February 17, 2016 01:45 PM BSUTTON ----- Need a supplemental ground rod for grounding electrode system. Need 8 digit premise number from progress energy to release service for power.
R229 02	2/19/16 <u>2.19.16</u>	TI <u>APBS</u>	TWO TRADE FINAL TIME: 17:00 VRU #: 002778314 T/S: 02/18/2016 08:15 AM LBENNETT -----

COMMENTS AND NOTES

