



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

November 8, 2016

Keith & Toni Beattie
195 Moonlight Drive
Fuquay Varina, NC 27526

RE: Existing Septic System Inspection HTE# 16-5-39976

Dear Mr. & Mrs. Beattie,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break lid free (\$25.00 fee incurred)

2. Have system pumped out

3. Replace sanitary T

4. Other – Replace lid on septic tank or replace handles on the tank.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

James E. Manhart, III, R.E.H.S.
Environmental Health OSWW Program Specialist
Harnett County Department of Public Health
Environmental Health

JEM/sgs
Copy - Central Permitting