

HTE# 17-500-40760

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Dean H. Sundquist PHONE # 919-639-6444

ADDRESS ^{RE:} 2918 Old Brier Creek Rd. Apic 27501

NAME OF MOBILE HOME PARK OR S/D NA

NAME OF OWNER (IF DIFFERENT) Same

ADDRESS OF OWNER (IF DIFFERENT) 2916 Old Brier Creek Rd Apic 27501

PROPERTY LOCATION: STATE ROAD NAME AND # Old Brier Creek Rd

PURPOSE OF INSPECTION: Storage Building

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

Appl A - Byrd R.E.H.S.
Signature of Environmental Health Specialist

3/3/17
Date