

HTE #: 17-5-41788

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: James Jennings Phone #: 401-570-5382

Address: 1170 St. George Dr. Annapolis, MD 21409

Name of Mobile Home Park or S/D: Atkins Village

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): Atkins Village - Lot 21 - Atkins Road (SR 1448)

Purpose of Inspection: Accessory - Shed (10'x16')

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

07/12/2017
Date