

HTE #: 18-5-43304

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Cumberland Homes Inc. Phone #: 910.892.4345

Address: P.O. Box 727 Dunn, NC 28335

Name of Mobile Home Park or S/D: The Reserve Lot 19

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 69 Trophy Ridge Fuquay-Varina, NC 27526

Purpose of Inspection: Accessory Detached Storage Building (28'x24'). No bathroom. No bedrooms. Proposed building not within septic field, repair area, or septic setbacks.

Partial Septic Relocated - reference 18-5-43304 operational permit.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

02/22/18

Date