

HTE #: 18-5-43900

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Wayne & Karen Harrenstein Phone #: 910.814.7344

Address: 72 Reserve Drive Fuquay-Varina, NC 27521

Name of Mobile Home Park or S/D: The Reserve Lot 4

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 72 Reserve Drive (Rollins Road - SR 1413)

Purpose of Inspection: Detached Storage Building (20'x24'). No bathroom. No bedrooms. Proposed building not within septic field, septic setbacks, or repair area.

Proposed power shall maintain within 5 foot mininum of home and porches.

**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

  
\_\_\_\_\_  
Signature of Environmental Health Specialist

05/11/2018  
Date