

HALLOWEN & ASSOCIATES, INC.

SOIL & ENVIRONMENTAL SCIENTISTS

P. O. Box 400, 266 Old Coats Road

Lillington, NC 27546

Phone (910) 893-8743 / Fax (910) 893-3594

E-mail: halowen@intrstar.net

14 May, 2001

Harnett County Environmental Health
P.O. Box 9
Lillington, NC 27546

Attention: Mr. Joe West

Reference: Detailed Soil Investigation And Septic System Design
Trade Center, Melvin and Geraldine Stewart Property (2.08 Acres)

Dear Mr. West,

It was my pleasure to meet with you at the above site to review the detailed soil investigation and septic system design proposed for the proposed commercial operation. The attached septic system design is for a wastewater flow of 1,500 gallons per day. Within this flow is a 16 ft by 54 ft carry-out pizza restaurant, which generates 432 gallons (50 gal/ 100 sqft), plus 100 gallons for four employees, for a total of 532 gallons. Inside the convenience store will be a deli, which consumes an area of about 16 ft by 20 ft, has two booths or 8 seats, and generates a flow of 480 gallons. The remaining area inside the convenience store constitutes 3,136 sqft and generates a flow of 376 gallons (120 gal/ 1000 sqft). The convenience store and deli will employ together four additional employees, or an additional 100 gallons of wastewater flow. Therefore, 532 gallons (pizza carry-out including 4 employees), 480 gallons (deli including eight seats), and 476 gallons (remaining convenience store including 4 employees to be shared with the deli) yields a total flow of 1,488 gallons per day. The attached septic system design is for a 1,500 gallon per day system and should be adequate for this establishment.

Pizza Carry-out

16 ft by 54 @ 50 gal/100 sqft	432 gallons
4 employees	100 gallons
Total	532 gallons

Deli

320 sqft (16 X 20) @ 50 gal / 100 sqft	160 gallons
8 seats @ 40 gal/ seat	320 gallons
Total	480 gallons

Convenience Store

3,136 sqft @ 120 gal/ 1000 sqft	376 gallons
4 employees (to be shared w/ deli)	100 gallons
Total	476 gallons

Grand Total 1,488 gallons

The proposed initial system and repair system both utilize pressure-manifold distribution into conventional drainlines that should be installed 18 to 24 inches below ground surface. Attached are the system layouts and the supporting information for the pressure-manifold designs. The supporting information is in a table form that has each component needed for a pressure-manifold system.

I trust that this report provides the information that you require at this time. If you have any questions or need additional information, please contact me at your convenience.

Sincerely,



Hal Owen
Licensed Soil Scientist



Trade Center "Stewart Property"

On-site Wastewater Design Specifications

Initial System (1500 gpd of flow)

Pressure-manifold into conventional drainlines
 (3 x 110', 2 x 105', 3 x 100' = 840 linear feet)
 on contour @ 18-24 inches
 LTAR: 0.6 gpd/sqft

Repair System (1500 gpd of flow)

Pressure-manifold into conventional drainlines
 (100, 130, 180, 80, 75, 60 = 625 linear feet)
 on contour @ 18-24 inches
 LTAR: 0.8 gpd/sqft



Lines flagged at site on 9-ft centers.







Initial/Repair	Line#	Line Color	Drainline Length(ft)	Measured Field Line Length(ft)	Relative Elevation(ft)
Repair	1	W	100	100	99.76
Repair	2	B	130	134	99.71
Repair	3	W	180	182	99.32
Repair	4	B	80	82	99.04
Repair	5	W	75	76	98.9
Repair	6	B	60	64	98.51
N/A	7	W	0	46	98.11
Initial	8	Y	110	113	99.37
Initial	9	W	110	111	99.38
Initial	10	B	110	112	99.39
Initial	11	W	105	106	99.31
Initial	12	B	105	106	99.24
Initial	13	W	100	101	99.16
Initial	14	Y	100	105	99.1
Initial	15	B	100	109	99.13
		Total:	1465	1547	☆ EIP = 100.00

Pressure Manifold Design Criteria

Line	Initial / Repair	Drainline Length(ft)	Tap Size/ Schedule	gpm/tap	gpm/ft	gpd/ft	LTAR (gpd/sqft)
8	Initial	110	3/4-80	10.1	0.092	1.70	0.57
9	Initial	110	3/4-80	10.1	0.092	1.70	0.57
10	Initial	110	3/4-80	10.1	0.092	1.70	0.57
11	Initial	105	3/4-80	10.1	0.096	1.79	0.60
12	Initial	105	3/4-80	10.1	0.096	1.79	0.60
13	Initial	100	3/4-80	10.1	0.101	1.87	0.63
14	Initial	100	3/4-80	10.1	0.101	1.87	0.63
15	Initial	100	3/4-80	10.1	0.101	1.87	0.63
						Target LTAR (gpd/sqft)=	0.60
						LTAR + 0.5%	0.63
						Daily PRT(min)=	18.56
Elev Hd(ft)=	To Be Determined	Friction Head(ft)=	To Be Determined	Pressure Head(ft)=	2	Dose PRT(min)=	5.09
		TDH =	To Be Determined	Total Flow (gpm)=	80.8	Dose Vol(gal)=	411.39 @ 75%

Prepared By:
 Hal Owen Associates, Inc
 Soil Environmental Scientists
 P.O.Box 400, 266 Old Coats Rd.
 Lillington, NC 27546-0400
 Phone: (910)893-8743




Pressure Manifold Design Criteria

Line	Initial / Repair	Drainline Length(ft)	Tap Size/ Schedule		gpm/tap	gpm/ft	gpd/ft	LTAR (gpd/sqft)
1	Repair	100	1/2-40	7.11 	10.665	0.101	2.37	0.79
2	Repair	130	1/2-40	7.11 	13.655	0.105	2.47	0.82
3	Repair	180	1-40	20.2 	18.5	0.103	2.42	0.81
4	Repair	80	1-80	16.8 	8.4	0.105	2.47	0.82
5	Repair	75	1/2-40	7.11 	7.11	0.095	2.23	0.74
6	Repair	60	1/2-80	5.5 	5.5	0.092	2.15	0.72
							Target LTAR	0.8
							LTAR + 0.5%	0.84
							Daily PRT(min)	23.5
					Pressure Head(ft)=	2	Dose PRT(min)	4.80
					Total Flow (gpm)=	63.83	Dose Vol(gal)=	306.09 @ 70%

Prepared By:
 Hal Owen Associates, Inc
 Soil Environmental Scientists
 P.O.Box 400, 266 Old Coats Rd.
 Lillington, NC 27546-0400
 Phone:(910)893-8743

Pressure Manifold Requirements

Trade Center
"Stewart Property"




Pressure Manifold 4" Schedule 80


Initial System

Line #	L8	L9	L10	L11
Line Length	110'	110'	110'	105'
	10.1	10.1	10.1	10.1
	3/4-80	3/4-80	3/4-80	3/4-80
	10.1	10.1	10.1	10.1
Line Length	100'	100'	100'	105'
Line #	L15	L14	L13	L12

Trade Center "St. art Property"





3000 GALLON SEPTIC TANK



2000 GALLON PUMP TANK

Trade Center "Stewart Property"



Grease \ 1000ggi

REINFORCEMENT: H-20 Bridge Loading
 CONCRETE: 4000 PSI @ 28 DAYS

Stay-Right
 Precast, Inc.

P.O. Box 58659
 Raleigh, NC 27658
 Phone (919) 876-8600
www.stayright.com

1000 Gallon Grease Interceptor