

HTE# 06-5-16001

Harmon County Department of Public Health

23298

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: T.C. JAMESPROPERTY LOCATION: Hwy 27

SUBDIVISION _____

LOT # 2NEW ☒ REPAIR ☐ EXPANSION ☐

Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: BUSINESS (9100R2)Proposed Wastewater System Type: CONVENTIONALProjected Daily Flow: 200 GPD (BASED ON WATER RECORDS)Number of bedrooms: 1 Number of Occupants: 6 EMP. maxBasement ☐ Yes ☒ NoPump Required: ☐ Yes ☐ No ☒ May be required based on final location and elevations of facilitiesType of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well 100 feet

Permit valid for:

☒ Five years

Permit conditions: _____

☐ No expirationAuthorized State Agent: [Signature]Date: 12/18/06

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: T.C. JAMESPROPERTY LOCATION: Hwy 27

SUBDIVISION _____

LOT # _____

Facility Type: BUSINESS ☒ New ☐ Expansion ☐ RepairBasement? ☐ Yes ☒ No Basement Fixtures? ☐ Yes ☐ NoType of Wastewater System** CONVENTIONAL (Initial)Wastewater Flow: 200 GPD(See note below, if applicable ☐)CONVENTIONAL

(Repair)

Installation Requirements/Conditions

2 TRENCHES

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Exact length of each trench 70 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 36 inches

(Trench bottoms shall be level to +/-1/4" in all directions)

Trench Spacing: 9 Feet on CenterSoil Cover: 24 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe2 inches above pipe

Conditions: _____

12 inches total

**If applicable:

I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature]

es (OLIVER TOLKSDORF)

Date: 12/18/06Construction Authorization Expiration Date: 12/18/11

HTE# 06-5-16001

Permit # 23298

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: Hwy 27

ISSUED TO: T.C. JAMES SUBDIVISION _____ LOT # _____

Authorized State Agent: ES (OLIVER TOURSPORE) Date: 12/18/06

