

HTE# 07-500 17992

Hartell County Department of Public Health

24285

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: DANNY KAY DAVIS II
PROPERTY LOCATION: RACING LANE
SUBDIVISION: George Williams
LOT #: 1A
Type of Structure: Shop - 1 Employee (100 sq ft min)
Proposed Wastewater System Type: GRAVEL
Projected Daily Flow: 240 GPD
Number of bedrooms: 0
Number of Occupants: 0 max
Basement: No
Pump Required: No
Type of Water Supply: Public
Permit conditions: STUB OUT PLUMBING SHALLOW, AT GROUND LEVEL OR HIGHER WHERE SHOWN MAINTAIN ALL SETBACKS

Authorized State Agent: J. LARS Date: 08-29-07 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: DANNY KAY DAVIS II
PROPERTY LOCATION: RACING LANE
SUBDIVISION: George Williams
LOT #: 1A
Facility Type: Shop (100 sq ft)
Basement? No
Type of Wastewater System: GRAVEL
Wastewater Flow: 240 GPD

Installation Requirements/Conditions

Septic Tank Size: 1000 gallons
Pump Tank Size:
Exact length of each trench: 2270 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6 inches
Maximum Trench Depth of: 1824 inches
Pump Requirements:
Aggregate Depth: 12 inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. LARS Date: 08-29-07 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 08-29-2012

HTE# 07-50017992

Permit # 24285

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Danny Kaye Paris III PROPERTY LOCATOR: Racing Lane  
SUBDIVISION: George Williams LOT # 1A

Authorized State Agent: Ju Lopez Date: 08-29-07

