



Plan Review, Inspection and Permit Fees

Application Number **08-50021260**

\$100.00	<input type="checkbox"/>	Explosive Materials (90 Days)
\$ 35.00	<input type="checkbox"/>	Explosive Materials (48 Hrs)
\$ 25.00	<input type="checkbox"/>	Fireworks Public Display
\$ 20.00	<input checked="" type="checkbox"/>	Final Inspection
\$ 25.00	<input type="checkbox"/>	Fire Alarm Testing
\$ 25.00	<input type="checkbox"/>	Fixed Fire Suppression
\$ 10.00	<input type="checkbox"/>	Insecticide Fog/Fumigation
\$ 50.00	<input type="checkbox"/>	Testing of Pipes/UST/AGST
\$ 50.00	<input checked="" type="checkbox"/>	Plans up to 5000 ft ²
\$100.00	<input type="checkbox"/>	Plans 5001 ft ² to 10,000 ft ²
\$150.00	<input type="checkbox"/>	Plans 10,001 ft ² to 25,000 ft ²
\$250.00	<input type="checkbox"/>	Plans 25,001 ft ² and over
\$ 25.00	<input type="checkbox"/>	Sprinkler Certification Test
\$ 25.00	<input type="checkbox"/>	Standpipe Testing
\$ 25.00	<input type="checkbox"/>	Special Assembly
\$ 10.00	<input type="checkbox"/>	Temporary Kiosks/Displays
\$ 10.00	<input type="checkbox"/>	Tents greater than 700 ft ²
\$ 50.00	<input type="checkbox"/>	Tank Installation (charge for each tank)
\$ 50.00	<input type="checkbox"/>	Tank Removal (charge for each tank)

\$ 70.00 Total

Michael L. Martin
 Code Enforcement Official

1/19/09
 Date

X2

Fire Marshal/Emergency Management	
Mailing: P. O. Box 370 Lillington, NC 27546 Physical: 200 North 13th Street, Suite 19 Erwin, NC 28339	910-893-7580 910-893-5025

APPLICATION FOR PLAN REVIEW

APPLICATION NUMBER: 08 - 50021260

TODAY'S DATE: 1.2.09 RECEIVED BY: d. duncan

SUBMITTED BY: Brandi McConnell

NAME OF PROJECT: McConnell Waste Systems & Recycling

PHYSICAL ADDRESS: Duncan Industrial # 4

PHONE NUMBER: _____ EXT.: _____

CONTACT PERSON: Brandi McConnell

MAILING ADDRESS: _____

PHONE NUMBER: 919.669.1212

CONTRACTOR'S NAME: _____

MAILING ADDRESS: _____

PHONE NUMBER: _____

NOTICE

PLANS THAT ARE SUBMITTED WILL BE REVIEWED AS QUICKLY AS POSSIBLE, WITH AN AVERAGE TIME OF REVIEW BETWEEN 7 - 10 WORKING DAYS.



January 19, 2009

Brandi McConnell
155 Progress Drive
Fuquay Varina, NC 27526

McConnell Waste Systems and Recycling
155 Progress Drive
Fuquay Varina, NC 27526

Application Number 08-50021260

Ms. McConnell,

Thank you for submitting the plans for the new storage building. The plans have been carefully reviewed by a qualified code enforcement official to examine for full compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **906.1 Fire Extinguishers**
 - Fire extinguishers shall be placed in approved locations as drawn by the code enforcement official on the approved plans.
 - The fire extinguishers provided shall have a minimum rating of 2A 10B:C and shall not be installed higher than 5 feet above the finished floor.

- **506.1 Knox Box**
 - A secure key box shall be installed on the new building that houses all keys to all the doors within the building in which the fire department would need access to in the event of an emergency.
 - Knox Box ID stickers shall be placed on all exterior doors in which entry to the building may be gained.
 - The box shall be mounted not to exceed 48 – 60 inches in height.
 - An authorized order form is included with this letter.

- **505.1 Physical Address**
 - The physical address of the building shall be posted in a conspicuous place so that it can be seen on approach from the road, access road, and/or parking lot.
 - The numbers used to make up the physical address shall be at least 5 inches in height


- **503.1.1 Fire Department Access**
 - The fire department access shall extend to within 150 feet of all portions of the facility.
 - The fire department access road shall be of an unobstructed width of not less than 20 feet and shall have an unobstructed vertical clearance of not less the 13 feet 6 inches.

- **508.5.1 Fire Hydrants**
 - In accordance with the Fire Code, a hydrant must be within 400' of a new occupancy classification in which your building would be categorized in.

Thank you again for submitting the plans for the new storage. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



Michael L. Martin
Deputy Fire Marshal

X2

Fire Marshal/Emergency Management	
Mailing: P. O. Box 370 Lillington, NC 27546 Physical: 200 North 13th Street, Suite 19 Erwin, NC 28339	910-893-7580 910-893-5025

APPLICATION FOR PLAN REVIEW

APPLICATION NUMBER: 08-50021260

TODAY'S DATE: 1-2-09 RECEIVED BY: d. duncan

SUBMITTED BY: Brandi McConnell

NAME OF PROJECT: McConnell Waste Systems & Recycling

PHYSICAL ADDRESS: Duncan Industrial #4

PHONE NUMBER: _____ EXT.: _____

CONTACT PERSON: Brandi McConnell

MAILING ADDRESS: _____

PHONE NUMBER: 919-669-1212

CONTRACTOR'S NAME: _____

MAILING ADDRESS: _____

PHONE NUMBER: _____

NOTICE

PLANS THAT ARE SUBMITTED WILL BE REVIEWED AS QUICKLY AS POSSIBLE, WITH AN AVERAGE TIME OF REVIEW BETWEEN 7 - 10 WORKING DAYS.