

PREPARED 11/17/10, 14:00:23  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 3  
DATE 11/18/10

-----  
ADDRESS . . : 3300 NC 82  
CONTRACTOR : TEW HENRY L  
OWNER . . . : AVERASBORO BATTLEFIELD  
PARCEL . . . : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
3300 NC 82 DUNN 28334. AVERASBORO  
BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
3300 NC 82 DUNN 28334.  
-----

STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS  
FLOOD ZONE . . . . : FLOOD ZONE X  
PROPOSED USE . . . . : NEW BUILD SEPTIC - EXISTING? . . . . : EXISTING  
-----

PERMIT: CBCO 00 CP BUILDING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C151 01	11/18/10 <u>11-18-10</u>	TI <u>AP</u>	C*BLDG FOOTING VRU #: 002008455

----- COMMENTS AND NOTES -----

PREPARED 11/22/10, 13:57:19  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 10  
DATE 11/23/10

-----  
ADDRESS . . : 3300 NC 82 SUBDIV:  
CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
OWNER . . : AVERASBORO BATTLEFIELD PHONE :  
PARCEL . . : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN -----  
3300 NC 82 DUNN 28334. AVERASBORO  
BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
3300 NC 82 DUNN 28334.  
-----

**STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS**

FLOOD ZONE . . . . : FLOOD ZONE X  
PROPOSED USE . . . . : NEW BUILD SEPTIC - EXISTING? . . . . : EXISTING

**PERMIT: CBCO 00 CP BUILDING COMMERCIAL**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C151 01	11/18/10 11/18/10	KS AP	C*BLDG FOOTING VRU #: 002008455
C155 01	11/23/10 <u>11-23-10</u>	TI <u>APBS</u>	C*BLDG FOUNDATION VRU #: 002010521

----- COMMENTS AND NOTES -----

PREPARED 12/08/10, 10:55:07  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 1  
DATE 12/08/10

-----  
ADDRESS . . : 3300 NC 82  
CONTRACTOR : TEW HENRY L  
OWNER . . . : AVERASBORO BATTLEFIELD  
PARCEL . . . : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
SUBDIV:  
PHONE : (910) 977-1288  
PHONE :

-----  
DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
3300 NC 82 DUNN 28334. AVERASBORO  
BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
3300 NC 82 DUNN 28334.

-----  
PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P351 01	12/08/10 12/08/10	BS CA	C*PLUMB ROUGH IN VRU #: 002016197 wrong inspection called in:52 AM BSUTTON -----
P357 01	12/08/10 <u>12-8-10</u>	TI <u>ABS</u>	C*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002016632 T/S: December 08, 2010 10:54 AM BSUTTON -----

----- COMMENTS AND NOTES -----

PREPARED 2/10/11, 13:56:42  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 5  
DATE 2/11/11

-----  
ADDRESS . . : 3300 NC 82 SUBDIV:  
CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
OWNER . . : AVERASBORO BATTLEFIELD PHONE :  
PARCEL . . : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
3300 NC 82 DUNN 28334. AVERASBORO  
BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
3300 NC 82 DUNN 28334.  
-----

**STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS**

FLOOD ZONE . . . . : FLOOD ZONE X  
PROPOSED USE . . . . : NEW BUILD SEPTIC - EXISTING? . . . . : EXISTING  
-----

**PERMIT: CBCO 00 CP BUILDING COMMERCIAL**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C151 01	11/18/10	KS	C*BLDG FOOTING VRU #: 002008455
	11/18/10	AP	
C155 01	11/23/10	BS	C*BLDG FOUNDATION VRU #: 002010521
	11/23/10	AP	T/S: November 23, 2010 10:29 AM BSUTTON -----
C159 01	2/11/11	TI	C*BLDG SLAB INSP VRU #: 002039733
	<u>2-11-11</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----  
-----

ADDRESS : 3300 NC 82 SUBDIV:  
 CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
 OWNER : AVERASBORO BATTLEFIELD PHONE :  
 PARCEL : 02-0595- - -0001- - -  
 APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
 DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
 3300 NC 82 DUNN 28334. AVERASBORO  
 BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
 3300 NC 82 DUNN 28334.

STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS  
 FLOOD ZONE : FLOOD ZONE X  
 PROPOSED USE : NEW BUILD SEPTIC - EXISTING? : EXISTING

PERMIT: CBCO 00 CP BUILDING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C151 01	11/18/10	KS	C*BLDG FOOTING VRU #: 002008455
	11/18/10	AP	
C155 01	11/23/10	BS	C*BLDG FOUNDATION VRU #: 002010521
	11/23/10	AP	T/S: November 23, 2010 10:29 AM BSUTTON -----
C159 01	2/11/11	KS	C*BLDG SLAB INSP VRU #: 002039733
	2/11/11	AP	
H824 01	3/24/11	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002059277
	3/24/11	AP	T/S: 03/25/2011 10:14 AM SZIMMER ----- T/S: 03/25/2011 10:14 AM SZIMMER -----
C153 01	4/04/11	TI	C*BLDG ROUGH IN VRU #: 002061878
	<u>4-4</u>	<u>DA</u>	

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E251 01	4/04/11	TI	C*ELEC ROUGH IN TIME: 17:00 VRU #: 002061984
	<u>4-4</u>	<u>DA</u>	T/S: 04/01/2011 01:53 PM JBROCK -----

PERMIT: CPMC 00 CP MECHANICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M459 01	4/04/11	TI	C*MECH ROUGH IN TIME: 17:00 VRU #: 002061992
	<u>4-4</u>	<u>AP</u>	T/S: 04/01/2011 01:53 PM JBROCK -----

PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P351 01	12/08/10	BS	C*PLUMB ROUGH IN VRU #: 002016197
	12/08/10	CA	wrong inspection called in:52 AM BSUTTON -----
P357 01	12/08/10	BS	C*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002016632
	12/08/10	AP	T/S: December 08, 2010 10:54 AM BSUTTON ----- T/S: December 08, 2010 11:02 AM BSUTTON -----
P351 02	4/04/11	TI	C*PLUMB ROUGH IN TIME: 17:00 VRU #: 002062008
	<u>4-4</u>	<u>AP</u>	T/S: 04/01/2011 01:53 PM JBROCK -----

COMMENTS AND NOTES

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-7525 Fax (910) 893-2793**

09-50023476

April 4, 2011

1. Nee receptacle at outside A/C unit
2. Door at rear cannot swing out over steps must have a 3 foot landing.
3. Steps on a commercial structure cannot exceed 7 in rise per step.

**Ken Slattum  
Building Code Administrator**

ADDRESS . . : 3300 NC 82 SUBDIV:  
 CONTRACTOR : TEW HENRY L. PHONE : (910) 977-1288  
 OWNER . . : AVERASBORO BATTLEFIELD PHONE :  
 PARCEL . . : 02-0595- - -0001- - -  
 APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
 DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
 3300 NC 82 DUNN 28334. AVERASBORO  
 BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
 3300 NC 82 DUNN 28334.

STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 PROPOSED USE . . . . : NEW BUILD SEPTIC - EXISTING? . . . . : EXISTING

PERMIT: CBCO 00 CP BUILDING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C151 01	11/18/10	KS	C*BLDG FOOTING VRU #: 002008455
	11/18/10	AP	
C155 01	11/23/10	BS	C*BLDG FOUNDATION VRU #: 002010521
	11/23/10	AP	T/S: November 23, 2010 10:29 AM BSUTTON -----
C159 01	2/11/11	KS	C*BLDG SLAB INSP VRU #: 002039733
	2/11/11	AP	
H824 01	3/24/11	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002059277
	3/24/11	AP	T/S: 03/25/2011 10:14 AM SZIMMER ----- T/S: 03/25/2011 10:14 AM SZIMMER -----
C153 01	4/04/11	KS	C*BLDG ROUGH IN VRU #: 002061878
	4/04/11	DA	T/S: 04/04/2011 02:02 PM KSLATTUM ----- Rear door cannot swing out over stairs. Stairs cannot have rise over 7 per step.
C153 03	4/15/11	TI	C*BLDG ROUGH IN TIME: 17:00 VRU #: 002068328
	4-15	AP	T/S: 04/14/2011 01:09 PM NTART -----
C153 02	4/15/11	TI	C*BLDG ROUGH IN TIME: 17:00 VRU #: 002068310
	4/14/11	CA	T/S: 04/14/2011 01:07 PM NTART ----- T/S: 04/14/2011 01:08 PM NTART -----

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E251 01	4/04/11	KS	C*ELEC ROUGH IN TIME: 17:00 VRU #: 002061984
	4/04/11	DA	T/S: 04/01/2011 01:53 PM JBROCK ----- T/S: 04/04/2011 02:08 PM KSLATTUM ----- Need a receptacle at outside ac unit
E251 02	4/15/11	TI	C*ELEC ROUGH IN TIME: 17:00 VRU #: 002068336
	4-15	AP	T/S: 04/14/2011 01:10 PM NTART -----
E265 01	4/15/11	TI	C*ELEC FINAL TIME: 17:00 VRU #: 002068302
	4/14/11	CA	T/S: 04/14/2011 01:07 PM NTART ----- T/S: 04/14/2011 01:09 PM NTART -----

COMMENTS AND NOTES

PREPARED 6/09/11, 15:07:22  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 1  
DATE 6/10/11

-----  
ADDRESS . : 3300 NC 82 SUBDIV:  
CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
OWNER . . : AVERASBORO BATTLEFIELD PHONE :  
PARCEL . . : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
-----

DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
3300 NC 82 DUNN 28334. AVERASBORO  
BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
3300 NC 82 DUNN 28334.  
-----

STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS

FLOOD ZONE . . . . : FLOOD ZONE X

PROPOSED USE . . . . : NEW BUILD

SEPTIC - EXISTING? . . . . : EXISTING  
-----

PERMIT: CPLU 00 CP LAND USE PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
Z820 01	6/10/11 <u>W/D/H</u>	TI <u>AP/AD</u>	PZ*ZONING/FINAL INSPECTION TIME: 17:00 VRU #: 002092914 T/S: 06/09/2011 03:07 PM NTART -----

----- COMMENTS AND NOTES -----  
-----



ADDRESS : 3300 NC 82 SUBDIV:  
CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
OWNER : AVERASBORO BATTLEFIELD PHONE :  
PARCEL : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
3300 NC 82 DUNN 28334. AVERASBORO  
BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
3300 NC 82 DUNN 28334.

STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS

FLOOD ZONE : FLOOD ZONE X  
PROPOSED USE : NEW BUILD SEPTIC - EXISTING? : EXISTING

PERMIT: CBCO 00 CP BUILDING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C151 01	11/18/10	KS	C*BLDG FOOTING VRU #: 002008455
	11/18/10	AP	
C155 01	11/23/10	BS	C*BLDG FOUNDATION VRU #: 002010521
	11/23/10	AP	T/S: November 23, 2010 10:29 AM BSUTTON -----
C159 01	2/11/11	KS	C*BLDG SLAB INSP VRU #: 002039733
	2/11/11	AP	
H824 01	3/24/11	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002059277
	3/24/11	AP	T/S: 03/25/2011 10:14 AM SZIMMER ----- T/S: 03/25/2011 10:14 AM SZIMMER -----
C153 01	4/04/11	KS	C*BLDG ROUGH IN VRU #: 002061878
	4/04/11	DA	T/S: 04/04/2011 02:02 PM KSLATTUM ----- Rear door cannot swing out over stairs. Stairs cannot have rise over 7 per step.
C153 03	4/15/11	KS	C*BLDG ROUGH IN TIME: 17:00 VRU #: 002068328
	4/15/11	AP	T/S: 04/14/2011 01:09 PM NTART -----
C153 02	4/15/11	TI	C*BLDG ROUGH IN TIME: 17:00 VRU #: 002068310
	4/14/11	CA	T/S: 04/14/2011 01:07 PM NTART ----- T/S: 04/14/2011 01:08 PM NTART -----
F854 01	6/09/11	TM	✓ FM*FINAL INSPECTION TIME: 17:00 VRU #: 002092385
	6/09/11	AP	T/S: 06/09/2011 12:29 PM TMCLAMB ----- T/S: 06/09/2011 12:29 PM TMCLAMB -----
C179 01	6/10/11	TI	C*BLDG FINAL VRU #: 002092728
	6/09/11	CA	MUST HAVE ZONING INSPECTION BEFORE FINAL. -----
C179 02	6/15/11	TI	C*BLDG FINAL TIME: 17:00 VRU #: 002094266
			T/S: 06/14/2011 08:01 AM NTART -----

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E251 01	4/04/11	KS	C*ELEC ROUGH IN TIME: 17:00 VRU #: 002061984
	4/04/11	DA	T/S: 04/01/2011 01:53 PM JBROCK ----- T/S: 04/04/2011 02:08 PM KSLATTUM ----- Need a receptacle at outside ac unit
E251 02	4/15/11	KS	C*ELEC ROUGH IN TIME: 17:00 VRU #: 002068336
	4/15/11	AP	T/S: 04/14/2011 01:10 PM NTART -----
E265 01	4/15/11	TI	C*ELEC FINAL TIME: 17:00 VRU #: 002068302
	4/14/11	CA	T/S: 04/14/2011 01:07 PM NTART -----

CONTINUED ONTO NEXT PAGE

PREPARED 6/14/11, 14:32:50  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 3  
DATE 6/15/11

ADDRESS : 3300 NC 82 SUBDIV:  
CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
OWNER : AVERASBORO BATTLEFIELD PHONE :  
PARCEL : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E265 02	6/10/11 6/09/11	TI CA	T/S: 04/14/2011 01:09 PM NTART C*ELEC FINAL TIME: 17:00 VRU #: 002092732 T/S: 06/09/2011 01:26 PM JBROCK MUST HAVE ZONING INSPECTION BEFORE FINAL
E265 03	<u>6-15</u>	TI <u>DA</u>	C*ELEC FINAL TIME: 17:00 VRU #: 002094274 T/S: 06/14/2011 08:01 AM NTART

PERMIT: CPMC 00 CP MECHANICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M459 01	4/04/11 4/04/11	KS AP	C*MECH ROUGH IN TIME: 17:00 VRU #: 002061992 T/S: 04/01/2011 01:53 PM JBROCK
M465 01	6/10/11 6/09/11	TI CA	C*MECH FINAL TIME: 17:00 VRU #: 002092740 T/S: 06/09/2011 01:27 PM JBROCK MUST HAVE A ZONING INSPECTION BEFORE FINAL
M465 02	<u>6-15</u>	TI <u>DA</u>	C*MECH FINAL TIME: 17:00 VRU #: 002094282 T/S: 06/14/2011 08:01 AM NTART

PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P351 01	12/08/10 12/08/10	BS CA	C*PLUMB ROUGH IN VRU #: 002016197 wrong inspection called in:52 AM BSUTTON
P357 01	12/08/10 12/08/10	BS AP	C*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002016632 T/S: December 08, 2010 10:54 AM BSUTTON T/S: December 08, 2010 11:02 AM BSUTTON
P351 02	4/04/11 4/04/11	KS AP	C*PLUMB ROUGH IN TIME: 17:00 VRU #: 002062008 T/S: 04/01/2011 01:53 PM JBROCK
P361 01	6/10/11 6/09/11	TI CA	C*PLUMB FINAL TIME: 17:00 VRU #: 002092757 T/S: 06/09/2011 01:27 PM JBROCK MUST HAVE ZONING INSPECTION BEFORE FINAL
P361 02	<u>6-15</u>	TI <u>DA</u>	C*PLUMB FINAL TIME: 17:00 VRU #: 002094308 T/S: 06/14/2011 08:02 AM NTART

----- COMMENTS AND NOTES -----

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-7525 Fax (910) 893-2793**

09-50023476

June 15, 2011

1. Need handicapped parking sign
2. Condensate drain shall exit to exterior or drain.
3. Need vertical grab bar and tp dispenser in correct location. See attached

**Ken Slattum  
Building Code Administrator**

PREPARED 6/16/11, 14:14:47  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 2  
DATE 6/17/11

-----  
ADDRESS : 3300 NC 82 SUBDIV:  
CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
OWNER : AVERASBORO BATTLEFIELD PHONE :  
PARCEL : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
DIRECTIONS : T/S: 12/23/2009 12:09 PM VBROWN ----  
3300 NC 82 DUNN 28334. AVERASBORO  
BATTLEFIELD. GO TO ERWIN TAKE 82 SOUTH  
3300 NC 82 DUNN 28334.  
-----

**STRUCTURE: 000 000 20X34 NEW BUILD RESTROOMS**

FLOOD ZONE . . . . : FLOOD ZONE X

PROPOSED USE . . . . : NEW BUILD

SEPTIC - EXISTING? . . . . : EXISTING

**PERMIT: CBCO 00 CP BUILDING COMMERCIAL**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C151 01	11/18/10	KS	C*BLDG FOOTING VRU #: 002008455
	11/18/10	AP	
C155 01	11/23/10	BS	C*BLDG FOUNDATION VRU #: 002010521
	11/23/10	AP	T/S: November 23, 2010 10:29 AM BSUTTON -----
C159 01	2/11/11	KS	C*BLDG SLAB INSP VRU #: 002039733
	2/11/11	AP	
H824 01	3/24/11	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002059277
	3/24/11	AP	T/S: 03/25/2011 10:14 AM SZIMMER ----- T/S: 03/25/2011 10:14 AM SZIMMER -----
C153 01	4/04/11	KS	C*BLDG ROUGH IN VRU #: 002061878
	4/04/11	DA	T/S: 04/04/2011 02:02 PM KSLATTUM ----- Rear door cannot swing out over stairs. Stairs cannot have rise over 7 per step.
C153 03	4/15/11	KS	C*BLDG ROUGH IN TIME: 17:00 VRU #: 002068328
	4/15/11	AP	T/S: 04/14/2011 01:09 PM NTART -----
C153 02	4/15/11	TI	C*BLDG ROUGH IN TIME: 17:00 VRU #: 002068310
	4/14/11	CA	T/S: 04/14/2011 01:07 PM NTART ----- T/S: 04/14/2011 01:08 PM NTART -----
F854 01	6/09/11	TM	FM*FINAL INSPECTION TIME: 17:00 VRU #: 002092385
	6/09/11	AP	T/S: 06/09/2011 12:29 PM TMCLAMB ----- T/S: 06/09/2011 12:29 PM TMCLAMB -----
C179 01	6/10/11	TI	C*BLDG FINAL VRU #: 002092728
	6/09/11	CA	MUST HAVE ZONING INSPECTION BEFORE FINAL. -----
C179 02	6/15/11	KS	C*BLDG FINAL TIME: 17:00 VRU #: 002094266
	6/15/11	DA	T/S: 06/14/2011 08:01 AM NTART ----- T/S: 06/15/2011 02:55 PM KSLATTUM ----- 1. Need handicapped parking sign 2. Condensate drain shall exit to exterior or drain. 3. Need vertical grab bar and tp dispenser in correct location. see page in code left at job site.
C179 03	6/17/11	TI	C*BLDG FINAL TIME: 17:00 VRU #: 002096089
	<u>6-17</u>	<u>AP</u>	T/S: 06/16/2011 12:30 PM DJOHNSON -----

**PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E251 01	4/04/11	KS	C*ELEC ROUGH IN TIME: 17:00 VRU #: 002061984

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS : 3300 NC 82 SUBDIV:  
 CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
 OWNER : AVERASBORO BATTLEFIELD PHONE :  
 PARCEL : 02-0595- - -0001- - -  
 APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	4/04/11	DA	T/S: 04/01/2011 01:53 PM JBROCK ----- T/S: 04/04/2011 02:08 PM KSLATTUM ----- Need a receptacle at outside ac unit
E251 02	4/15/11	KS	C*ELEC ROUGH IN TIME: 17:00 VRU #: 002068336
	4/15/11	AP	T/S: 04/14/2011 01:10 PM NTART -----
E265 01	4/15/11	TI	C*ELEC FINAL TIME: 17:00 VRU #: 002068302
	4/14/11	CA	T/S: 04/14/2011 01:07 PM NTART ----- T/S: 04/14/2011 01:09 PM NTART -----
E265 02	6/10/11	TI	C*ELEC FINAL TIME: 17:00 VRU #: 002092732
	6/09/11	CA	T/S: 06/09/2011 01:26 PM JBROCK ----- MUST HAVE ZONING INSPECTION BEFORE FINAL-----
E265 03	6/15/11	KS	C*ELEC FINAL TIME: 17:00 VRU #: 002094274
	6/15/11	DA	T/S: 06/14/2011 08:01 AM NTART ----- T/S: 06/15/2011 02:55 PM KSLATTUM ----- 1. Need handicapped parking sign 2. Condensate drain shall exit to exterior or drain. 3. Need vertical grab bar and tp dispenser in correct location. see page in code left at job site.
E265 04	6/17/11	TI	C*ELEC FINAL TIME: 17:00 VRU #: 002096097
	<u>6/17</u>	<u>AP</u>	T/S: 06/16/2011 12:30 PM DJOHNSON -----

PERMIT: CPMC 00 CP MECHANICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M459 01	4/04/11	KS	C*MECH ROUGH IN TIME: 17:00 VRU #: 002061992
	4/04/11	AP	T/S: 04/01/2011 01:53 PM JBROCK -----
M465 01	6/10/11	TI	C*MECH FINAL TIME: 17:00 VRU #: 002092740
	6/09/11	CA	T/S: 06/09/2011 01:27 PM JBROCK ----- MUST HAVE A ZONING INSPECTION BEFORE FINAL-----
M465 02	6/15/11	KS	C*MECH FINAL TIME: 17:00 VRU #: 002094282
	6/15/11	DA	T/S: 06/14/2011 08:01 AM NTART ----- T/S: 06/15/2011 02:55 PM KSLATTUM ----- 1. Need handicapped parking sign 2. Condensate drain shall exit to exterior or drain. 3. Need vertical grab bar and tp dispenser in correct location. see page in code left at job site.
M465 03	6/17/11	TI	C*MECH FINAL TIME: 17:00 VRU #: 002096105
		<u>AP</u>	T/S: 06/16/2011 12:30 PM DJOHNSON -----

PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P351 01	12/08/10	BS	C*PLUMB ROUGH IN VRU #: 002016197
	12/08/10	CA	wrong inspection called in:52 AM BSUTTON -----
P357 01	12/08/10	BS	C*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002016632

CONTINUED ONTO NEXT PAGE

PREPARED 6/16/11, 14:14:47  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 4  
DATE 6/17/11

-----  
ADDRESS . : 3300 NC 82 SUBDIV:  
CONTRACTOR : TEW HENRY L PHONE : (910) 977-1288  
OWNER . . : AVERASBORO BATTLEFIELD PHONE :  
PARCEL . . : 02-0595- - -0001- - -  
APPL NUMBER: 09-50023476 CP NEW COMMERCIAL BLDG/ENTERPRISE  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	12/08/10	AP	T/S: December 08, 2010 10:54 AM BSUTTON ----- T/S: December 08, 2010 11:02 AM BSUTTON -----
P351 02	4/04/11	KS	C*PLUMB ROUGH IN TIME: 17:00 VRU #: 002062008
	4/04/11	AP	T/S: 04/01/2011 01:53 PM JBROCK -----
P361 01	6/10/11	TI	C*PLUMB FINAL TIME: 17:00 VRU #: 002092757
	6/09/11	CA	T/S: 06/09/2011 01:27 PM JBROCK ----- MUST HAVE ZONING INSPECTION BEFORE FINAL-----
P361 02	6/15/11	KS	C*PLUMB FINAL TIME: 17:00 VRU #: 002094308
	6/15/11	DA	T/S: 06/14/2011 08:02 AM NTART ----- T/S: 06/15/2011 02:55 PM KSLATTUM ----- 1. Need handicapped parking sign 2. Condensate drain shall exit to exterior or drain. 3. Need vertical grab bar and tp dispenser in correct location. see page in code left at job site.
P361 03	6/17/11	TI	C*PLUMB FINAL TIME: 17:00 VRU #: 002096121
	<u>6-17</u>		T/S: 06/16/2011 12:30 PM DJOHNSON -----

----- COMMENTS AND NOTES -----

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: \_\_\_ Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Bathrooms

**Permit Numbers**

Name: Aversboro Battlefield

Building: 09-50023476

6-14 A.P.

Electrical: 09-50023476

Address: 3300 NC 82

Insulation: 09-50023476

Plumbing: 09-50023476

Mechanical: 09-50023476

MFG Home: \_\_\_\_\_

Date: 6-17-11

Building Official: \_\_\_\_\_

Ke State