

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:

Address:

Proposed Facility: *WALTON*

Date Evaluated: *12/14/16*  
 Design Flow (.1949): *150 gpd*

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public  Individual  Well

Spring  Other

Evaluation Method:  Auger Boring

Pit  Cut

Mixed

Type of Wastewater:

Sewage  Industrial Process

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>LS 2-5</i>	<i>0-24</i>	<i>GS</i>	<i>VFZNS/NP</i>					
		<i>24-42</i>	<i>SBK SCL</i>	<i>F2 SS/SP</i>					<i>PS .24</i>
		<i>42</i>	<i>PM</i>						
2		<i>0-30</i>	<i>GS</i>	<i>VFZNS/NP</i>					
		<i>30-36</i>	<i>SBK SCL</i>	<i>F2 SS/SP</i>					
		<i>36</i>	<i>PM</i>						<i>PS .35</i>
3		<i>0-25</i>	<i>GS</i>	<i>VFZNS/NP</i>					
		<i>25-42</i>	<i>SBK SCL</i>	<i>F2 SS/SP</i>					<i>PS .44</i>
		<i>42</i>	<i>PM</i>						

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>OI</i> Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>CONCRETE</i>		
Site LTAR	<i>.35</i>	<i>.35</i>	