

RJB, P.E., P.A.

C-0269

ROBERT J. BRACKEN
ENGINEER + SURVEYOR

3768 Carbonton Road • Sanford, North Carolina 27330
(919) 774-6074 • bjbracken@windstream.net

43351

April 9, 2018

Harnett County Inspections
P. O. Box 65
Lillington, NC 27546

REF: Anderson Creek Landfill
Maintenance Facility
Revision to approved Plans
Harnett County, NC 27546

Dear Sir /Madam,

I have no problem removing the #57 stone under the turned down lug footing only.
The rest of the slab area shall have the stone as specified. The drop lug will support
the live and dead loads that will be placed on it and meets or exceed the requirements set
forth in the NC State Building Code, 2012, ed.

If you have any questions call 919-774-6074.

Sincerely,

Robert J. Bracken

Robert J. Bracken, PE

RJB

