

Harnett County

Inspections
108 East Front Street
Lillington , NC 27546

Phone: 910-893-7525
Fax: 910-893-2793

Inspection Report

Permit: CSED17-50042439

OWNER: CAMPBELL UNIVERSITY

Site Address: 445 LESLIE CAMPBELL AVE LILLINGTON, NC 27546

Harnett County Inspections Department

Inspection Type: HOOD SYSTEM

Inspection Date: 03/27/2020

Result: DISAPPROVED

Remarks:

Notes: All hoods tested complete. Only issue found is non capture/containment at solid fuel smoker under hood #4.
Provide correction and reschedule performance test

BS 3/24/2020 1:36:44 PM
Kitchen hoods finals

All violations are subject to reinspection fees at the inspectors discretion.

Brad Sutton
Inspector