

00-5-0638

# OPERATIONS PERMIT

Name: (owner) MARCUS RAY ADCOCK       New Installation       Septic Tank  
 Property Location: SR# Hwy 210       Repairs       Nitrification Line  
 Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: OTIS STRICKLAND      Registration # \_\_\_\_\_

Basement with Plumbing:       Garage:   
 Water Supply:  Well       Public       Community  
 Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional       Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons      Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field: No. of ditches 1      exact length 450 ft.      width of ditches 3 ft.      depth of ditches 18 in.  
 French Drain: \_\_\_\_\_ Linear feet

Date: 10/29/01  
 Inspected by: [Signature]  
 Environmental Health Specialist

PERMIT NO. 16832

Pump CON. REPAIR

