

#00 5000922

HAMILTON COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

No 10886

# OPERATIONS PERMIT

Name: (owner) Jo Perry Whetton  New Installation  Septic Tank  
 Property Location: SR# 421  Repairs  Nitrification Line  
 Subdivision Myrtlewood Lot # 24  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Kenneth Weekes Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 133 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain: \_\_\_\_\_ Linear feet

Date: 5-14-01

PERMIT NO. 16766  
#00-5000922

Inspected by: James E. Marshall III  
Environmental Health Specialist

