

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Paul Roberts / Womble Residential Court.  New Installation  Septic Tank  
Property Location: SR# 401 N  Repairs  Nitrification Line

Subdivision Donniebrook Lot # 20

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: .574 Ac

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community number

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other Polystyrene Aggregate Trench System TWAJ-45-70

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18 in. MAX


French Drain Required: \_\_\_\_\_ Linear feet

Date: 3/1/2001

**This permit is subject to revocation if site plans or intended use change.**

Signed: Bryan M. Swain R.S.  
105 Environmental Health Specialist

\* Maintain all setbacks  
C/1/1 \* Run ditches on contour &  
NO DEEPER than 18 inches



HARNETT COUNTY HEALTH DEPARTMENT  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17571. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent \_\_\_\_\_

Name: Paul Roberts / Wamble Residential Const Telephone # 814-0383

Address: P.O. Box 187 Boies Creek NC, 27506

Property Location: SR # 401 Road Name \_\_\_\_\_

New Installation  Repair  Septic Tank  Nitrification Lines

Subdivision Donice brook Lot # 20

Number of Bedrooms Proposed: 3 Lot size: .574Ac

Basement  With Plumbing  Without Plumbing

Water Supply: Well  Public  Minimum Well Setback: 50 ft.

Type of System: Conventional  Other Polystyrene Aggregate Trench System Ewws-85-3A

Tank Volume: Septic Tank 1000 gallons Pump Chamber \_\_\_\_\_ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 4 Length of lines 80ft.

Width of ditches 3 ft. Depth of ditches 18 inches MAX

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Dwain McJannet L.S. Date: 3/1/2001