

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-18	0-12	0-12	0-24										
Texture Group	.1941(A)(1)	LS	LS	LI	LS										
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 2 DEPTH		18-30	12-24	12-24	24-32										
Texture Group	.1941(A)(1)	SCL	SCL	SCL	SCL										
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 3 DEPTH		30-38	24-36	24-36	32-36										
Texture Group	.1941(A)(1)	SC	SC	SL	SC										
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942			30"											
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948														
LONG TERM ACCEPTANCE RATE	.1955														

LPP
LTPR
-1 AT
18" MAX

Deny
Well,
AV. SPACE
MAY MOVE
HOUSE LPP
SYSTEM & RYZM