

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L	L						
SLOPE (%)	.1940	2	2	2	2						
HORIZON 1 DEPTH		0-8	0-8	0-8	0-5						
Texture Group	.1941(A)(1)	SL	SL	SL	SL						
Consistence	.1941	FR	FR	FR	FR						
Structure	.1941(A)(2)	GR	GR	GR	GR						
Mineralogy	.1941(A)(3)	NSNP	NSNP	NSNP	NSNP						
HORIZON 2 DEPTH		8-12	8-12	8-12	5-10						
Texture Group	.1941(A)(1)	SCL	SCL	SCL	SCL						
Consistence	.1941	FR	FR	FR	FR						
Structure	.1941(A)(2)	ARM	ARM	ARM	ARM						
Mineralogy	.1941(A)(3)	SSSP	SSSP	SSSP	SSSP						
HORIZON 3 DEPTH		12-36	12-36	12-36	10-24						
Texture Group	.1941(A)(1)	SL CL	SL CL	SL CL	SL CL						
Consistence	.1941	FR	FR	FR	FR						
Structure	.1941(A)(2)	GR	GR	GR	GR						
Mineralogy	.1941(A)(3)	SSSP	SSSP	SSSP	SSSP						
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948	PS	PS	PS	V						
LONG TERM ACCEPTANCE RATE	.1955	.4	.4	.4	-						

