

IMPROVEMENT PERMIT 01-5-1453

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Custom Contracting
Property Location: SR# 1201
New Installation, Septic Tank, Repairs, Nitrification Line

Subdivision CAROLINA SEASONS Lot # A-16

Tax ID # Quadrant #

Number of Bedrooms Proposed: 3 (33x52) Lot Size: 13x175 - .49 AC

Basement with Plumbing: Garage:

Water Supply: Well, Public, Community

Distance From Well: 55 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other

Size of tank: Septic Tank: 1000 gallons Pump Tank: gallons


Subsurface Drainage Field No. of Ditches: 1 exact length of each ditch: 200 ft. width of ditches: 3 ft. depth of ditches: 18 1/2 in.

French Drain Required: Linear feet

Date: 03-14-01

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature] Environmental Health Specialist



STUB out Plumbing shallow where shown - 18 to 24" Ditch Depth
Follow contours maintain all set backs - Do not Drive or Park on septic Area

HARNETT COUNTY HEALTH DEPARTMENT  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 18267. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Custom Contracting

Name: \_\_\_\_\_ Telephone # 775-1497

Address: \_\_\_\_\_

Property Location: SR# 1201 Road Name \_\_\_\_\_

New Installation  Repair \_\_\_\_\_ Septic Tank  Nitrification Lines

Subdivision CAROLINA SEASON Lot # A-16

Number of Bedrooms Proposed: 3 (30x52) Lot size: 0.49 AC

Basement \_\_\_\_\_ With Plumbing \_\_\_\_\_ Without Plumbing \_\_\_\_\_

Water Supply: Well \_\_\_\_\_ Public  Minimum Well Setback: \_\_\_\_\_ ft.

Type of System: Conventional  Other \_\_\_\_\_

Tank Volume: Septic Tank 1000 gallons Pump Chamber \_\_\_\_\_ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 1 Length of lines 220

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: [Signature] Date: 03-14-01