

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Quest Dev. Co. Inc New Installation Septic Tank
 Property Location: SR# 1513 Repairs Nitrification Line

Subdivision Springfield Lot # 21

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: .6 ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50+ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of exact length width of depth of
 Ditches 2 of each ditch 170 ft. ditches 3 ft. ditches 12 in.

French Drain Required: 160 approx Linear feet

Date: 7-9-99

Signed: Thomas J. Boyer R.S.
 Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.



Maintain Setbacks
 Contractor to meet on site
 prior to installing
 Owner to maintain drainage
 of site

**HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT**

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 16203. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Quest Dev. Co. INC

Name: _____ Telephone # 639-2937

Address: P.O. Box 2121 Dunn NC

Property Location: SR # 1513 Road Name _____

New Installation Repair _____ Septic Tank Nitrification Lines

Subdivision Springfield Lot # 21

Number of Bedrooms Proposed: 3 Lot size: .6 ac

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public Minimum Well Setback: 50+ ft.

Type of System: Conventional Other _____

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 2 Length of lines 120

Width of ditches 3 ft. Depth of ditches 12 inches

French Drain: Linear feet required 160' Depth of gravel 3'

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Thomas Q. Boyce R.S. Date: 7-9-99