

OPERATIONS PERMIT

Name: (owner) Cape Fear Builders New Installation Septic Tank
Property Location: SR# 1443 Repairs Nitrification Line
Subdivision Victoria Hills II Lot # 196
TAX ID# _____ Quadrant # _____
Contractor: Ott: r Str: ckland Registration # _____
Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 4 of each ditch 75 ft. ditches 3 ft. ditches 18-24 in.
French Drain: _____ Linear feet

PERMIT NO. 17596

Date: 8/15/201
Inspected by: Bryan McLeod
Environmental Health Specialist

