

OPERATIONS PERMIT

OHS-1763

Name: (owner) Danny Norris

New Installation Septic Tank

Property Location: SR# 1115

Repairs Nitrification Line

Subdivision Crestview

Lot # 79

TAX ID# _____

Quadrant # _____

Contractor: T. Brown

Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 55 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 70 ft. width of ditches 3 ft. depth of ditches 18.24 in.


French Drain: _____ Linear feet

Could not read 2

Date: 9-27-01

PERMIT NO. _____

Inspected by: Joe L. ...
Environmental Health Specialist



RE