

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-20	0-10	-18	0-3	0-12									
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL									
Consistence	.1941	VF	VF	VF	VF	VF									
Structure	.1941(A)(2)	G	G	G	G	G									
Mineralogy	.1941(A)(3)	NEV	NEV	NEV	NEV	NEV									
HORIZON 2 DEPTH		20-24	14-24	18-20	3-24	12-24									
Texture Group	.1941(A)(1)	SCl	SCl	SCl	CL	CL									
Consistence	.1941	R	R	R	R	R									
Structure	.1941(A)(2)	SBK	SBK	SBK	SBK	SBK									
Mineralogy	.1941(A)(3)	SOV	SOV	SOV	SOV	SOV									
HORIZON 3 DEPTH		3-4		3-4											
Texture Group	.1941(A)(1)	SAP		SAP											
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942		24"												
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956	34"		30"											
CLASSIFICATION	.1948	PS	PS												
LONG TERM ACCEPTANCE RATE	.1955	.3	.3	.4	.4	.4									

24.



①

②

③

④

⑤