

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L								
SLOPE (%)	.1940	5-7	5-7								
HORIZON 1 DEPTH		0-6	0-6	0-10	0-12						
Texture Group	.1941(A)(1)	S2	S2	SL/WH	Fill						
Consistence	.1941	VFR	VFR	VFR							
Structure	.1941(A)(2)	G	G	G							
Mineralogy	.1941(A)(3)	SEXP	SEXP	SEXP							
HORIZON 2 DEPTH		7"+	7"+	10-20"	12-18"						
Texture Group	.1941(A)(1)	PM	PM	SC/E	SL						
Consistence	.1941			FR	VFR						
Structure	.1941(A)(2)			SBK	G						
Mineralogy	.1941(A)(3)			SEXP	NOX						
HORIZON 3 DEPTH				20-25"	18-26"						
Texture Group	.1941(A)(1)			SCL	SCI						
Consistence	.1941			FR	F						
Structure	.1941(A)(2)			SBK	SBK						
Mineralogy	.1941(A)(3)			SEXP	SEXP						
HORIZON 4 DEPTH				30"+							
Texture Group	.1941(A)(1)			CL							
Consistence	.1941			FR							
Structure	.1941(A)(2)			SBK							
Mineralogy	.1941(A)(3)			SEXP							
SOIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948	U3	U3	PS	PS						
LONG TERM ACCEPTANCE RATE	.1955			.4	.4						

