

#01-5-2192

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15401

OPERATIONS PERMIT

Name: (owner) CUMMIN BUILDERS INC

New Installation Septic Tank

Property Location: SR# 1542 OLD BUIES CREEK

Repairs Nitrification Line

Subdivision Jandy Grove

Lot # 25

TAX ID# _____

Quadrant # _____

Contractor: Hal Brown

Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain: _____ Linear feet

Date: 10-9-02

PERMIT NO. 18464

Inspected by: James E. Mansueti
Environmental Health Specialist

