

1-5-2595

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Timothy + Daphne Baker New Installation Septic Tank
Property Location: SR# 1769 Old Stage South Repairs Nitrification Line

Subdivision Deer Path Farms Lot # 4

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 4.3 Ac

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Pump to Conventional

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18 in.


French Drain Required: _____ Linear feet

Date: 8/14/2001

Signed: Dwight McSwain R.S.
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

- * Maintain all setbacks
- * Run ditches on contour
- * Supply line from pump tank approximately 50 ft to Distribution box



HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 18015. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent _____

Name: Timothy + Daphne Baker Telephone # 919-207-1321

Address: 50 Mingo Rd. Benson, N.C. 27504

Property Location: SR# 1769 Road Name Old Stage South

New Installation Repair Septic Tank Nitrification Lines

Subdivision Deer Park Farms Lot # 4

Number of Bedrooms Proposed: 3 Lot size: 4.3 Ac

Basement With Plumbing Without Plumbing

Water Supply: Well Public Minimum Well Setback: 50 ft.

Type of System: Conventional Other Pump to Conventional

Tank Volume: Septic Tank 1000 gallons Pump Chamber 1000 gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 3 Length of lines 100 ft

Width of ditches 3 ft. Depth of ditches 18 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Bryce McSwain R.S. Date: 8/14/2001