

IMPROVEMENT PERMIT

01-5-2942

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Weaver Dev. New Installation Septic Tank
Property Location: SR# 1141 Repairs Nitrification Line

Subdivision Sunset Ridge Lot # 56

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (32x62) Lot Size: 3910

Basement with Plumbing: Garage: *Please note that this*

Water Supply: Well Public Community *lot has fill placed on it*

Distance From Well: 30 ft. *18 to 30" Deep SYSTEM must be placed below*

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to *The* final approval. *Fill*

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 3 exact length 80 ft. width of 3 ft. depth of 18 to 24 in.

French Drain Required: _____ Linear feet *12" Below Fill*

Date: 9-19-01

This permit is subject to revocation if site plans or intended use change.

Signed: Joe W. [Signature]
Environmental Health Specialist



Please note This lot ~~is~~ has fill placed on it At least 18 to 30" Deep - SYSTEM must be placed At least 12" Below Fill - MUST meet on site - ~~is~~

MAINTAIN ALL SETBACKS - Do not Drive or Park on septic SYSTEM - 1st Line to start at least 10' from Rear Property Line

HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 18525. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Weaver Dev.

Name: _____ Telephone # 630 2100

Address: _____

Property Location: SR # 1141 Road Name _____

New Installation Repair _____ Septic Tank Nitrification Lines

Subdivision Sunset Ridge Lot # 54

Number of Bedrooms Proposed: 3 (32x62) Lot size: ~39 AC

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public Minimum Well Setback: _____ ft.

Type of System: Conventional Other _____

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 3 Length of lines 80

Width of ditches 3 ft. Depth of ditches 18.24 inches 12" Below F.I.

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department
Name: Joe L. [Signature] Date: 9-19-01