

# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME \_\_\_\_\_

DATE \_\_\_\_\_

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-38	0-16	5-14											
Texture Group	.1941(A)(1)	SL/LS	LS	LS											
Consistence	.1941	VFR		VFR											
Structure	.1941(A)(2)	G		G											
Mineralogy	.1941(A)(3)	NS/MP		NS/MP											
HORIZON 2 DEPTH		38-44	16-30	24-30											
Texture Group	.1941(A)(1)	SC2	SEL	SC2											
Consistence	.1941	FR		FR											
Structure	.1941(A)(2)	G/SK		SBK											
Mineralogy	.1941(A)(3)	SS/SP		SS/SP											
HORIZON 3 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942		26												
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	PS	PC	PS											
LONG TERM ACCEPTANCE RATE	.1955	.8	.4	.5											

SEE LAYOUT ON BACK OF MAP