


SITE SOIL EVALUATION FOR ON-LINE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940	0-2													
HORIZON 1 DEPTH		0-4	0-16	0-20											
Texture Group	.1941(A)(1)	SC2	S	S											
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 2 DEPTH		12-18	16-38	20 ⁺											
Texture Group	.1941(A)(1)	S	C	C											
Consistence	.1941	VFR	FR/F	FR											
Structure	.1941(A)(2)	SG	SBK	SEK											
Mineralogy	.1941(A)(3)	NS/SP	SS/P	SS/P											
HORIZON 3 DEPTH		18-36													
Texture Group	.1941(A)(1)	C													
Consistence	.1941	FR/R													
Structure	.1941(A)(2)	SBK													
Mineralogy	.1941(A)(3)	SS/P													
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942	36"	38"	36"											
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	P3	P5	P5											
LONG TERM ACCEPTANCE RATE	.1955	3	3	3											



4 100' LINES
 18 - 25" DEEP
 START @ 18" NEAR HOUSE
 RUN INTO SLOPE (.6°)
 9' ON CENTER
 CON. REPAIR