

# SITE/ IL EVALUATION FOR ON- WASTEWATER

APPLICANT NAME \_\_\_\_\_

DATE \_\_\_\_\_

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L							
SLOPE (%)	.1940	2	2	2							
HORIZON 1 DEPTH		0-30	0-30	0-30							
Texture Group	.1941(A)(1)	SL	SL	SL							
Consistence	.1941	PH	PH	PH							
Structure	.1941(A)(2)	GR	GR	GR							
Mineralogy	.1941(A)(3)	NSNP	NSNP	NSNP							
HORIZON 2 DEPTH		30-42	30-42	30-42							
Texture Group	.1941(A)(1)	SCL	SCL	SCL							
Consistence	.1941	GR	SOPH	GR							
Structure	.1941(A)(2)	GR	GR	GR							
Mineralogy	.1941(A)(3)	NSNP	NSNP	NSNP							
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	36w	36w	36w							
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948										
LONG TERM ACCEPTANCE RATE	.1955	.5	.5	.5							