

#01-5-3402

ARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 13706

OPERATIONS PERMIT

Name: (owner) A.L. Champion New Installation Septic Tank
 Property Location: SR# 1443 LARNEY HILL RD Repairs Nitrification Line
 Subdivision Victoria Hills Lot # 200
 TAX ID# _____ Quadrant # _____
 Contractor: Ray Moore Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 4 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-20 in.
 French Drain: _____ Linear feet

01-5-3402 Date: 2-28-02
 PERMIT NO. 18639 Inspected by: James E. Marshall
 Environmental Health Specialist

