

# SITE/SC" EVALUATION FOR ON-SIT WASTEWATER

APPLICANT NAME \_\_\_\_\_

DATE \_\_\_\_\_

FACTORS		PROFILES												
		1	2	3	4	5	6	7	8	9	10			
LANDSCAPE POSITION	.1940													
SLOPE (%)	.1940													
HORIZON 1 DEPTH		0-8	0-12	0-16										
Texture Group	.1941(A)(1)	SL	SL	SL										
Consistence	.1941	VF	VF	VF										
Structure	.1941(A)(2)	G	G	G										
Mineralogy	.1941(A)(3)	W	W	W										
HORIZON 2 DEPTH		8-24	11-22	16-30										
Texture Group	.1941(A)(1)	C	SC	C										
Consistence	.1941	F	F	F										
Structure	.1941(A)(2)	SBK	SBK	SBK										
Mineralogy	.1941(A)(3)	SC	SC	SC										
HORIZON 3 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
HORIZON 4 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
SOIL WETNESS	.1942	24"		20"										
RESTRICTIVE HORIZON	.1944													
SAPROLITE	.1943/.1956													
CLASSIFICATION	.1948	SP	PI	PI										
LONG TERM ACCEPTANCE RATE	.1955	.3	.3	.7										

P4  
E  
 0  
 

(2)

**Required Property Line Setbacks**

	Minimum	Actual
Front	35	244
Side	10	45
Corner	20	
Rear	25	185
Nearest Building	10	

N.C.S.R. 1516 - Sheriff-Johnson Rd.  
60' R/W (Public Dedicated)

6'18"W 220.76'

S 03°35'16"E 118.00' N 89°25'50"E 32.00'

ECS  
Base of Dogwood

#BEDROOMS 4  
DATE 04 Feb 02  
Zoning Administrator C Bell

SITE PLAN APPROVAL  
DISTRICT BA-40 USE SFD

202.59' 00°49'43"E

Drive Way  
S 08°33'46"E 181.74'  
0.067 Ac.

234  
244

Driveway



Lavern E. Gaskin  
& Donna D. Gaskin  
D.B. 516, Page 177

10' Sewer Easement

EIS 10.00' N 16°57'30"W

N 73°02'30"E 74.26'

S 73°02'30"W 71.36'

S 00°49'43"E 243.41' (Total)

82.39'

ISS 85.22' N 51°50'16"E

37.00' 122.22' (Total)

N 84°33'01"E 267.06' (Total)  
215.89'

**Required Property Line Setbacks**

	Minimum	Actual
Front	35	244
Side	10	45
Corner	20	
Rear	25	185
Nearest Building	10	

SITE PLAN APPROVAL

DISTRICT BA 40 USE SFD


#BEDROOMS 4

2-4-02 C Williams  
Zoning Administrator  
C Bell

385.79' S 84°41'12"W

Lavern E. Gaskin  
D.B. 845, Pg. 909  
28.5+- Ac. Residual

in 09



5X110  
 18" depth  
 on  
 center