

02-11-3950

NETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

No 15209

# OPERATIONS PERMIT

Name: (owner) Gibson Contractor  New Installation  Septic Tank  
 Property Location: SR# 1439  Repairs  Nitrification Line  
 Subdivision Adam Point Lot # 3  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Mike Ray Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:  Permitted for 3 bedrooms  
 Water Supply:  Well  Public  Community  
 Distance From Well: 80 ft.


**Following are the specifications for the sewage disposal system on above captioned property.**

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-21 in.  
 French Drain: \_\_\_\_\_ Linear feet

Date: 8/13/2002

PERMIT NO. 17676

Inspected by: Bryan M. Smith  
Environmental Health Specialist



rd.