

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-12"	0-12"	0-10"											
TEXTURE GROUP	.1941(A)(1)	SL	SL	SL											
CONSISTENCE	.1941	VFR	VFR	VFR											
STRUCTURE	.1941(A)(2)	CR/G	G	G											
MINERALOGY	.1941(A)(3)	NS/NP	NS/NP	NS/NP											
HORIZON 2 DEPTH		14"	18"	10"											
TEXTURE GROUP	.1941(A)(1)	SC2	SC2	CL/C											
CONSISTENCE	.1941	FR	FR	FR											
STRUCTURE	.1941(A)(2)	SBK	SBK	SBK											
MINERALOGY	.1941(A)(3)	SS/SP	SS/SP	SS/SP											
HORIZON 3 DEPTH															
TEXTURE GROUP	.1941(A)(1)														
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
HORIZON 4 DEPTH															
TEXTURE GROUP	.1941(A)(1)														
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
SOIL WETNESS	.1942	42"													
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	PS	PS	PS											
LONG TERM ACCEPTANCE RANGE	.1955	.4	.4	.35											

300'
 4x75
 18"-24"
 ON CONTOUR
 LPP REP
 MEET ON SITE
 PRIOR TO ANY
 INSTALLATION

